



City of WOODSTOCK

Department of Community Development
121 W. Calhoun Street
Woodstock, Illinois 60098

phone 815.338.4305
fax 815.338-2264
communitydevelopment@woodstockil.gov
www.woodstockil.gov

April 22, 2014

TO: *Building Board of Construction Commission Members*

There will be a Building Board of Commission meeting on Tuesday, April 29, 2014 at 7:00 p.m. in the Conference Room (2nd Floor). Any members unable to attend should contact the Department of Community Development (338-4305) prior to noon the day of the meeting.

AGENDA

1. Call to Order at 7:00 p.m.
2. Approval of Minutes
3. Request for a variance on the requirement to install a fire sprinkler system at Coleman's Restaurant 823 Lake Ave. Coleman's is proposing to add an addition of 160 sq. ft. The building code currently requires any A-2 use (restaurant) that has an occupant load of 100 or more people to have an automatic fire sprinkler system. Coleman's restaurant currently doesn't have a sprinkler system with an occupant load of 117 people.
4. Adjourn